


# HEALTH DEPARTMENT DISTRICT JIND



## Hygienic Certificate

Certified that Dy. Civil Surgeon (School Health) O/o Civil Surgeon Jind inspected the premises on 19.01.2026. and found the hygienic and sanitation condition of Nav Durga Public School Assandh Road Safidon Jind. satisfactory for the session 2025-2026.

Dy. Civil Surgeon (School Health)  
For Civil Surgeon Jind

*[Signature]*  
19/01/2026

Memo No. Hygienic/CSJind/2025-26/257

Dated : 19/01/2026

*[Signature]*

PRINCIPAL

NAV DURGA PUBLIC SCHOOL (S31155)  
ASSANDH ROAD, SAFIDON, JIND  
HARYANA - 128112

President

*[Signature]*  
Nav Durga Education Society  
Jind (Haryana) 126192

Memo No:- 35

Date:- 12/01/2026

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : JND/07755/1/2026 / Private	<b>Sample Details</b>	<b>Date &amp; Time</b>
Sender : Nav Durga Public School ,Safidon Jind	Collected By	Sh. Vipul Shar...
Location : Vill. Rodh, Safidon	Collection Date	06/01/2026 at 14:19
Sample Description : Drinking Water	Received at lab	06/01/2026 at 15:22
Latitude / Longitude : 76.633351 / 29.465420	Analysis Start Date	06/01/2026
	Analysis End Date	08/01/2026
	Sample Quantity	2ltr

**Test Result (As Per BIS 10500 :2012)**

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.21	1 NTU	5 NTU	APHA 24th Edition-2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):1984 (2023)
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):1984 (2018)
4	Color	5.0	5 Hazen Units	15 Hazen Units	APHA 24th Edition-2120-B
5	Total Dissolved Solids @ 180°C ± 2°C	113	500 mg/lt.	2000 mg/lt.	APHA 24th Edition-2540 C
6	Total Hardness as CaCo3	24.24	200 mg/lt.	600 mg/lt.	APHA 24th Edition-2340 C
7	Calcium as Ca	3.24	75 mg/lt.	200 mg/lt.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	3.93	30 mg/lt.	100 mg/lt.	APHA 24th Edition-3500 Mg B
9	Total Alkalinity	18	200 mg/lt.	600 mg/lt.	APHA 24th Edition-2320 B
10	Chloride as Cl	14.89	250 mg/lt.	1000 mg/lt.	APHA 24th Edition-4500 Cl-B
11	Sulphate as So4	9	200 mg/lt.	400 mg/lt.	APHA 24th Edition-4500 SO4E
12	Fluoride as F	0.12	1.0 mg/lt.	1.5 mg/lt.	APHA 24th Edition-4500F C
13	Iron as Fe	0.00	1.0 mg/lt.	1.0 mg/lt.	USEPA,APHA 24rd Edition-3500 Fe B
14	Nitrate as No3	0.15	45 mg/lt.	45 mg/lt.	APHA 24th Edition-4500 NO3 D
15	pH @ 25°C	7.17	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition-4500-H+ B

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in PHED JIND Lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.
- \* The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

VIRENDER ,CHEMIST  
DISTRICT WATER TESTING LABORATORYJIND  
email:-chemist.jind@phedharyana.gov.in

*Vipul Sharma*

**PRINCIPAL**

NAV DURGA PUBLIC SCHOOL (531155)  
ASSANDH ROAD, SAFIDON, JIND  
HARYANA - 126112

*S. B. D. S.*  
**President**  
Nav Durga Education Society  
Jind (Haryana) 126102